



Test Summary: PASS



Date / Time: 10/29/2010 11:59:02am
Headroom: 3.0 dB (NEXT 36-45)
Test Limit: TIA C6A 2m Patch (LA)
 Cable Type: Cat 6A FTP

Operator: CHRIS
 Software Version: 2.2400
 Limits Version: 1.3700
 NVP: 74.0%

Model: DTX-1800
 Main S/N: 9446013
 Remote S/N: 9446014
 Main Adapter: DTX-LAB7
 Remote Adapter: DTX-LAB7



Wire Map (T568B)

PASS



Length (ft)	[Pair 12]	8
Prop. Delay (ns)	[Pair 12]	11
Delay Skew (ns)	[Pair 12]	0
Resistance (ohms)	[Pair 12]	62.0

	Worst Case Margin		Worst Case Value	
	MAIN	SR	MAIN	SR
PASS				
Worst Pair	36-45	36-45	36-45	36-45
NEXT (dB)	3.0	9.9	3.0	9.9
Freq. (MHz)	478.0	478.0	478.0	478.0
Limit (dB)	29.1	29.1	29.1	29.1



	Worst Case Margin		Worst Case Value	
	MAIN	SR	MAIN	SR
PASS				
Worst Pair	36	36	36	12
RL (dB)	2.2	6.2	2.2	7.7
Freq. (MHz)	491.0	200.5	491.0	456.0
Limit (dB)	9.6	15.0	9.6	10.1

